

Verification Certificate

This is to certify that:

Plumis Ltd
Unit 4
Phoenix Trading Estate
Bilton Rd
Perivale
UB6 7DZ
United Kingdom

Holds Certificate Number:

VC 712581

In respect of:

Multi-head "Smartsan" targeted water mist fire suppression system as described in Automist Smartsan Hydra Design, Installation, Operation and Maintenance Manual V1.5.1.



For and on behalf of BSI:

Frank Lee, Product Certification Technical and Compliance Director

First Issued: 2019-06-28

Latest Issue: 2022-06-23

Effective Date: 2022-06-28

Expiry Date: 2025-06-27

Page: 1 of 2

...making excellence a habit.™

Verification Certificate

No. VC 712581

Product:

Automist Smartsan Hydra

Multi-head "Smartsan Hydra" targeted water mist fire suppression system as described in;

- Automist Smartsan Hydra Design, Installation, Operation and Maintenance Manual V1.5.1. dated April 2019
- Plumis Automist Smartsan Hydra Technical document List dated April 2019
- Plumis Kit List dated Jan 2019

Specification:

Performance requirements of BS 8458:2015 – Fixed fire protection systems. Residential and domestic watermist systems. Code of practice for design and installation.

As verified in:

Exova Warringtonfire report: 396489 Issue 1, dated 23 April 2018
BS 8458:2015 Annex C.

Exova Warringtonfire report: 347811 Issue 1, dated 13 March 2015
Test on watermist system utilising the principles of the procedure defined in BS 9252:2011: Annex S

First Issued: 2019-06-28

Latest Issue: 2022-06-23

Effective Date: 2022-06-28

Expiry Date: 2025-06-27

Page: 2 of 2

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

BSI Assurance UK Limited, registered in England under number 7805321 at 389 Chiswick High Road, London W4 4AL, UK.
A member of BSI Group of Companies.